

Audio Sound Advice Portable Appliance Test Results.				Customer :- The Love Rats, Party Band					
PAT Tester SEAWARD PAT500H Serial Number :- S10 - 0779				Tested by P.Bawden Of Audio Sound Advice.					
				Test Date :- 23/09/2011					
Item	Manufacturer.	Model.	Serial Number	Protective Earth Test+/-	Insulation P / N Test	Leakage P/N/E mA.	Visual	Pass/Fail	Actions / Notes.
1	QTX Light	Hazer FX 1000	N/A	0.189 0.191	<19.9Mohms	0.01	OK	Passed	13 Amp Fused
2	American DJ	46 HP LED	36454099	0.181 0.178	<19.9Mohms	0.01	OK	Passed	1A Internally Fused
3	American DJ	46 HP LED	36454187	0.137 0.141	<19.9Mohms	0.01	OK	Passed	1A Internally Fused
4	American DJ	46 HP LED	36454098	0.139 0.136	<19.9Mohms	0.01	OK	Passed	1A Internally Fused
5	American DJ	46 HP LED	36454097	0.113 0.115	<19.9Mohms	0.01	OK	Passed	1A Internally Fused
6	Behringer	RX1220RX	N0704557488	0.139 0.139	<19.9Mohms	1.07	OK	Passed	1.6A Internally Fused
7	Yamaha	P5000S	Jx01007	0.181 0.189	<19.9Mohms	0.49	OK	Passed	13 Amp Integral Lead
8	Martin Audio	MA2.8s	00116560	0.088 0.087	<19.9Mohms	0.71	OK	Passed	10 Amp Internally Fused
9	Martin Audio	MA2.8s	08410026	0.03 0.029	<19.9Mohms	1.22	OK	Passed	10 Amp Internally Fused
10	Martin Audio	DX1	000148	0.114 0.111	<19.9Mohms	0.28	OK	Passed	500mA Internally Fused
11	Martin Audio	MA4.2	105-019	0.031 0.03	<19.9Mohms	0.87	OK	Passed	13 Amp Fused
12	PR Lighting	Pilot 150	Missing	0.091 0.094	<19.9Mohms	0.52	OK	Passed	6.3 Amp Internally Fused
13	PR Lighting	Pilot 150	Missing	0.109 0.111	<19.9Mohms	0.53	OK	Passed	6.3 Amp Internally Fused
14	PR Lighting	Pilot 150	4001310013004060000.00	0.162 0.119	<19.9Mohms	0.54	OK	Passed	6.3 Amp Internally Fused
15	PR Lighting	Pilot 150	A05763	0.095 0.084	<19.9Mohms	0.56	OK	Passed	6.3 Amp Internally Fused
16	Yamaha	PA300B	08KM12	Class II	<19.9Mohms	0.03	OK	Passed	Sealed SM P.S.U.
17	QTX	1.7.083	N/A	Class II	<19.9Mohms	0.03	OK	Passed	9V Multiple Power Supply
18	JTS	SIEM-111T	A6803201T3.4%6.7%11.13-003	0.179 0.176	<19.9Mohms	0.39	OK	Passed	500mA Internally Fused
19	JTS	SIEM-111T	A6803201T3.4%6.7%11.13-002	0.184 0.181	<19.9Mohms	0.38	OK	Passed	500mA Internally Fused
20	Showtec	Dynamic	N/A	0.066 0.065	<19.9Mohms	0.07	OK	Passed	2 Amp Internally Fused
21	JTS	aheadjed-1200600f	N/A	Class II	<19.9Mohms	0.03	OK	Passed	3 Amp Adapter
22	JTS	aheadjed-1200600f	N/A	Class II	<19.9Mohms	0.03	OK	Passed	3 Amp Adapter
23	Roland	RD-150	AQ77120	Class II	<19.9Mohms	0.23	OK	Passed	Internally Fused
24	B&Q	F1102/L500	N/A	0.097 0.096	<19.9Mohms	0.01	OK	Passed	Floodlights
25	B&Q	F1102/L500	N/A	0.085 0.083	<19.9Mohms	0.01	OK	Passed	Floodlights
26	Blyss	HF/45	N/A	0.074 0.069	<19.9Mohms	0.02	OK	Passed	Fans
27	Blyss	HF/45	N/A	0.122 0.119	<19.9Mohms	0.03	OK	Passed	Fans
28	Line 6	DC1GUK	N/A	Class II	<19.9Mohms	0.03	OK	Passed	SMPS
29	NA	Mega Bar Equivilent	N/A	0.079 0.065	<19.9Mohms	0.03	OK	Passed	Internally Fused
30	NA	Mega Bar Equivilent	N/A	0.080 0.067	<19.9Mohms	0.03	OK	Passed	Internally Fused
31	NA	Mega Bar Equivilent	N/A	0.089 0.076	<19.9Mohms	0.02	OK	Passed	Internally Fused
32	NA	Mega Bar Equivilent	N/A	0.072 0.08	<19.9Mohms	0.03	OK	Passed	Internally Fused
33	NA	Tri Phase Equivilent	N/A	Fail	Fail	Fail	Fail	Fail	NOT TO BE USED
34	NA	Tri Phase Equivilent	N/A	Fail	Fail	Fail	Fail	Fail	NOT TO BE USED
35	Presonus	Studio Live 16:4:2	PG1A020211	0.08 0.079	<19.9Mohms	0.01	OK	Passed	Internally Fused